KLARK TEKNIK GROUP

TECHNICAL BULLETIN

Walter Nash Road, Kidderminster, Worcestershire. DY11 7HJ. England **Tel:** (44) (0) 1562 741515. **Fax:** (44) (0) 1562 745371

KLARK TOTAL MIDES SIGNAL PROCESSING BY DEFINITION BETTER BY DESIGN DESIGNED FOR A PURE PERFORMANCE

Brand	Reference Number	Date	☐ Urgent
Midas	126	17/04/2003	Recommended
Product	Serial Number	Assembly	Information Only
Legend 3000	Applied from 3361 onwards	Output Meters LC3	311C and LC321C
Subject	TT TO THE STATE OF		
Frequency response of output met	ters is low at 20kHz.		
Information			
It has been observed while carrying out frequency sweeps of Legend outputs that the			
response of the output meters is not flat and will drop off as the frequency increases			
above 10kHz.			
above Tokriz.			
This is a feature of the output meter circuitry and does not affect the audio path in any			
way. To improve the output meters response at higher frequencies the following			
resistors need to be changed from a 30k 1% 0603 package Metal film resistor to a 10k			
1% 0603 package Metal film resistor. (Klark Teknik Part Number RES56-4E1R00)			
170 0003 package Metal Inni resistor. (Rank rental rate Manie Resistor)			
A MA DOD I COLL			
Aux Meter PCB LC311			
Resistors: R102, R202, R302, R402, R502, R602, R702, R802, R902, R1002, R1102			
and R1202.			
Group/ST Aux Return/Matrix Meter PCB LC321			
Resistors: R102, R202, R302, R402, R502, R602, R702, R802, R902, R1002, R1102			
and R1202.			
As all of the meters are identical circuitry only one page of the schematics has been			
shown with the resistors highlighted. The board overlay is also included with the			
resister positions highlighted.			
positions inginigh	ii.		
Other Information			
	Г		
Distributed All Distributes		Date Distributed	
All Distributors		09/06/2003	

Legend Output Module Overview

The Output module assembly part number is ALC311-5 (If you order complete tested output modules it is part number L311). The individual sub assembly part numbers are displayed below.









